

PHEV Design Impacts

Jason Taylor Ph.D.

**South West Electric Distribution
Exchange**

May 6th, 2010

Annual Energy Usage – Electrical Appliances

Home Heating System **2,136 kWh**

Central Air Conditioning **3,475 kWh**

Refrigerator/Freezer **1,359 kWh**

Water Heater **2,552 kWh**

VOLT **1890 kWh**

Clothes Dryer **1,079 kWh**

Lighting **1839 kWh**

TV + Others **4182 kWh**

Volt is approx. 10% load increase to the average home

NISSAN LEAF
Zero Emission **2964 kWh**


Nissan Leaf is approx. 15% load increase to the average Home

[1] 2005 Residential Energy Consumption Survey

[2] AEO2009, EIA, national average for 2009 data

Electrical Charging Characteristics (Load Diversity)

- Demand will vary spatially across the feeder
 - Market penetration
 - System configuration
 - Socio-economics
- Demand will vary temporally
 - Driving patterns
 - Battery size
 - Electrical connection




Near-term System Impacts

- Per-capita load growth
- First generation vehicles
- PEV operate only as *uncontrolled load*
- Most likely impacts from PEV clusters
 - *Thermal overload*
 - *Customer low voltage*

Evaluated Distribution Impacts

- Thermal Overloads
- Steady-state Voltage
- Losses
- Imbalance

Evaluating Thermal Overload Risk



Impact Likelihood (Thermal Overload)

Stochastic Analysis Low Penetration Case

ckt	Case w/ Overloads	Avg Overloads per Case	# Xfmr Involved
A	95%	2.9	43
B	17%	1.0	4
C	2%	1.0	2
D	1%	1.0	1
E	30%	1.2	11
F	98%	2.5	4
G	14%	1.0	1

Impact likelihood is system dependent

Only a small percentage are likely to be impacted

Feeder A



300 Transformers

14% at risk


1% likely impacted

Likelihood Factors (System Design)

- Existing asset loading
- Customers served
- Number of assets
- Asset ratings



Likelihood Factors (Market Penetration)



Near-Term Steady-State Impacts

- PEV clustering impacts most likely on assets:
 - Close to the customer
 - Low capacity per customer
- Few clusters at low penetration levels
- Possible planning standards adjustments
 - Transformer sizing
 - Asset/Customer allocations
 - Transformer thermal ratings



Chevrolet Volt
Extended Range EV
40-mile EV range
16kWh Li-Ion
Intro: 2010 CY


Transformer Loss of Insulation Life

- Thermal aging is system and *condition* specific


~~What impact will PEVs have on aging?~~

What impacts can I expect on my system?


- Assets at risk
- Likelihood of impact
- PEV conditions
- Severity



Impact Mitigation



**Equivalent aging as one
240V/30A peak hour
charge**



**Controlled charging can
minimize impact as
adoption increases**

Power Quality Concerns

- EPRI current performing laboratory testing
- Infrastructure Working Council (IWC) Recommendations
 - Total power factor < 95%
 - Total harmonic current distortion (THD) $\leq 20\%$ at full rated power
 - Current distortion at each harmonic
 - IEC 1000-3-2



Harmonics

Power Quality Concerns

- Limit in-rush current to 28/56 A peak for 120/240 V
- Random start over 10 minute period after outage

**Flicker
&
In-Rush**

- 90% to 110% of nominal
- 180% of nominal for 2 cycles
- 6kV surge (ANSI C62.41-1991)
- 80% sag for 2 seconds

**Voltage
Tolerances**

Phase II Efforts

- A well integrated AMI infrastructure or a more comprehensive distribution transformer load management program will help address many distribution issues

- **Phase II Effort –**

- **Utility PHEV Charging Demo studies**

- Validate models and customer behavior data
 - Validate planning criteria based on real-time data

- **Collect real-time data from transformers and AMI system**

- Conduct utility specific loss-of-life and thermal ratings evaluation of assets

